



City of Lindsay

DEPARTMENT OF CITY SERVICES

P.O. Box 369 — Lindsay, California 93247 — 150 North Mirage Ave.

559 • 562 • 7102 Option 4

559 • 562 • 5/48 tax



December 23, 2025

Lindsay Generators Project

Addendum/Clarification No. 2

The following additions and/or corrections shall become part of the Specifications for the subject project:

1. Revised RFQ Schedule

To allow additional time for proposer inquiries and the City's review process, the following updates have been made to the RFQ schedule:

- a. Deadline for RFQ Questions:
December 29, 2025, by 4:00 p.m.
- b. RFQ Submittal Deadline:
January 5, 2026, by 2:00 p.m.
- c. Tentative Interview Week:
Week of January 5, 2026
- d. City Council Award Date:
January 13, 2026


2. Question/Clarification.

Question 1:

Item 4(b) suggests a Mechanical Engineer. Can this be omitted if the approach is a diesel generator system with integral mechanical components? Are there any requirements for gas on-site?

Response:

The City does not currently require on-site gas systems for this project. Diesel generator systems are anticipated. Proposers shall ensure that all necessary mechanical expertise is provided as required to support the proposed generator system, including fuel systems and ancillary components. A separate mechanical subconsultant is not required if the prime consultant can adequately demonstrate the capability to address mechanical elements within their team. Mechanical design services shall be provided as required based on site-specific conditions and system needs.



Question 2:

The RFQ references enclosure or housing design “if required.” Can the City provide guidance on the number of sites likely to require enclosures or screening?

Response:

Based on the City’s preliminary assessment and project objectives, the City recommends that enclosure and/or screening be evaluated and assumed at all seven (7) project sites for purposes of proposal development. Enclosures or screening may be required to address considerations such as noise attenuation, security, aesthetics, and code compliance. Final enclosure type, extent, and design details will be confirmed during Phase 1 design on a site-by-site basis.

Proposers should account for this recommendation in their approach and cost proposal.

This completes the items included in this Addendum/Clarification No. 2 for the City of Lindsay, **Lindsay Generators Project**. This Addendum cover page shall be signed and submitted with RFQ submittal.

Consultant

Date