

Addendum #3

June 29, 2026

Lindsay Wellness Center

Pool Deck Renovation Project

DATE:6/24/26

Q: On plan sheet L-002 the slot drain is shown in a U-shape. Since the slot drain pipe is 6" schedule 40 pvc and not flexible, is there another piping material intended to use here that can bend and follow the deck design at this location?

A: Sheet L-002 has been revised. Curved portion of the slot drain on plan sheet L-002 has a radius of 50'-5 3/4". For the curved portion of the slot drain on plan sheet L-002 please use 6" IPS SDR 11 HDPE PE4710 Pipe. See minimum bend radius below:

Minimum bending radius – IPS pipe							
IPS Pipe Size	PE4710	B & S	PVC Fused	IPS Pipe Size	PE4710	B & S	PVC Fused
1 1/2	5 ft	32 ft	–	16	40 ft	267 ft	333 ft
2	6 ft	40 ft	–	18	45 ft	300 ft	375 ft
2 1/2	7 ft	48 ft	–	20	50 ft	333 ft	417 ft
3	9 ft	58 ft	73 ft	24	60 ft	400 ft	500 ft
4	11 ft	75 ft	94 ft	30	75 ft	500 ft	–
6	17 ft	110 ft	138 ft	36	90 ft	600 ft	–
8	22 ft	144 ft	180 ft	42	105 ft	700 ft	–
10	27 ft	179 ft	224 ft	48	120 ft	800 ft	–
12	32 ft	213 ft	266 ft	54	135 ft	–	–
14	35 ft	233 ft	292 ft				

Q: At the Therapy pool, the depth tile markers are in the area to be demoed. Please advise if we are replacing these with the new deck. Picture attached for clarity. If yes, please provide specifications and details:

A: Yes, the depth tile markers will need to be replaced around the therapy pool in qty. 7 locations. Sheet L-003 and X-001 have been revised accordingly. Please reference plan sheet N-001 "Permanent markings" for depth tile specifications, CBC chapter 31B for Public pools, and detail 6 on sheet D-002.

Q: Please confirm medium brush finish on all new concrete.

A: Yes, medium brush finish on all new concrete. Concrete notes have been revised on sheets L-001, L-002, L-003, L-005.

Corrections: Plans have been revised to Revision C. Please identify all revisions with revision cloud C.

The following sheets have been revised:

X-001

SP-001

L-001

L-002

L-003

L-005

BP-002

D-001

D-002

I acknowledge receipt of Addendum #3 as described above:

Signature: _____

Printed Name: _____

Company: _____

Date: _____